

Upper Array, Individual Panel Test 2/4/20 2:45-3:10pm, intermittent cloud cover

Number 1 adjacent to array isolation switch

Panel Type	#	Voc	Isc -	Isc+	Average	
					Δ Voc	Δ Isc
PowerWave 270W	1	34.24	9.42	9.8	-11.52%	6.29%
PowerWave 270W	2	33.81	9.7	10.1	-12.64%	9.54%
PowerWave 270W	3	33.69	9.4	10.06	-12.95%	9.11%
PowerWave 270W	4	33.65	9.55	9.67	-13.05%	4.88%
PowerWave 270W	5	33.57	9.5	9.55	-13.26%	3.58%
PowerWave 270W	6	33.57	9.36	9.66	-13.26%	4.77%
PowerWave 270W	7	33.52	9.2	10.06	-13.39%	9.11%
PowerWave 270W	8	33.43	9.3	9.35	-13.62%	1.41%
PowerWave 270W	9	33.39	9.39	9.4	-13.72%	1.95%
PowerWave 270W	10	33.36	9.42	9.77	-13.80%	5.97%
PowerWave 270W	11	33.41	9.2	9.88	-13.67%	7.16%
PowerWave 270W	12	33.55	9.12	9.51	-13.31%	3.15%
Trina 250W	13	32.24	8.8	9.13	-15.16%	3.87%
Trina 250W	14	32.16	8.27	9.14	-15.37%	3.98%
Trina 250W	15	32.26	8.34	8.74	-15.11%	-0.57%
Solon 225W	16	32.01	8.44	8.86	-13.02%	15.82%
Solon 225W	17	31.95	8.4	8.86	-13.18%	15.82%
Solon 225W	18	31.82	8.36	8.89	-13.53%	16.21%
Solon 225W	19	31.87	8.28	8.58	-13.40%	12.16%
Solon 225W	20	31.78	8.12	8.93	-13.64%	16.73%
Solon 225W	21	31.86	8.47	8.73	-13.42%	14.12%

Nameplate	Voc	Isc
Powerwave 270W	38.7	9.22
Trina 250W	38	8.79
Solon 225W	36.8	7.65